

SECTION A - A

NOTES:

1. MAY BE CIRCULAR OR SQUARE. JOINT TO BE SMOOTH AND UNIFORM CLASS 3300 -3/4" CONCRETE, 4-6% ENTRAINED AIR.
2. ALL REINFORCING STEEL SHALL BE ASTM A615.
3. SET CONCRETE 1/4" BELOW A.C. FINISH GRADE.
4. PLACE CLSM BACKFILL IN EXCAVATION AREAS AS DIRECTED.

JACKSON COUNTY ROADS

MIKE KUNTZ, P.E.
COUNTY ENGINEER


Date	By	Revision

JCRD104:
MONUMENT/ VALVE BOX ADJUST

\\Engineering\LIBRARY\COUNTY\STD_DWG\2017\RD100-Miscellaneous\JCRD104-ValveAdjust.dwg

OCT 2017

NO SCALE



JACKSON COUNTY
Roads