




**NEW CONSTRUCTION
ROADWAY/DRIVEWAY/SIDEWALK**




**EXISTING PAVED
ROADWAY/DRIVEWAY/SIDEWALK**
SURFACE REPLACEMENT: SEE GENERAL




ROADWAY SECTION



**GRAVEL RD.
/DRIVEWAY
(DETAIL)**



OUTSIDE ROADWAY SECTION



* 3/4"-0 AGG. MAY BE ALLOWED ON A CASE BY CASE APPROVAL IF PRE-APPROVED BY THE COUNTY ENGINEER.

NOTES:

- ADD 4" TO PIPE BEDDING/PIPE ZONE THICKNESS FOR PIPES W/ BELLS.
- ALL UTILITIES SHALL HAVE A MINIMUM DEPTH OF 30"(36" FOR ELECTRICAL).
- ALL UTILITIES REQUIRING 1-SACK CLSM SHALL BE AT A DEPTH THAT ALLOWS 1' MIN. THICKNESS OF CLSM, THIS MAY REQUIRE THE UTILITY TO BE PLACED BELOW THE MINIMUM 30"DEPTH (36" FOR ELECTRICAL) REQUIREMENT.
- STORM DRAINS OR CULVERTS REQUIRING CLSM SHALL HAVE A MIN. 1' THICKNESS OF CLSM, THIS MAY REQUIRE 1-SACK CLSM IN THE PIPE ZONE.
- 3/4"-0 AGG. MAY BE SUBSTITUTED FOR CLSM IN EXISTING PAVED DRIVEWAYS WITH CONCRETE OR CMP CULVERT INSTALLATIONS. THIS SUBSTITUTION NOT ALLOWED FOR ANY OTHER UTILITY WITHOUT THE ENGINEERS' APPROVAL.
- SAND SEAL ALL AC JOINTS.
- REPLACE GRAVEL SURFACE W/ SAME. REPLACE OIL MAT SURFACE W/ 2" AC PATCH. REPLACE AC SURFACE WITH 4" AC PATCH, PLACED IN 2" MAX. LIFTS. REPLACE P.C.C. PAVING TO EXISTING THICKNESS W/ 3300 PSI CONC., PLACE CLSM TO BOTTOM OF CONCRETE.
- MATERIALS AND CONSTRUCTION METHODS SHALL COMPLY W/ JACKSON COUNTY'S SPECIAL PROVISIONS, OR STANDARD SPECIFICATIONS.
- PROVIDE STEEL JUMP PLATES, JUMP PLATE LOCKS, SIGNAGE AND OTHER PROTECTIVE MEASURES AS DIRECTED.
- LONGITUDINAL TRENCHES GREATER THAN 100' IN LENGTH WITHIN TRAVEL LANE SHALL HAVE EXISTING PAVEMENT REMOVED AND REPLACED TO FULL LANE WIDTH (NORMALLY 10'-12') FOR LENGTH OF TRENCH UNLESS APPROVED OTHERWISE BY JACKSON COUNTY. DRAG BOXES OR OTHER PULL-TYPE ASPHALT SPREADERS WILL NOT BE PERMITTED FOR LANE RESTORATION.
- STEEL PLATES SHALL BE REMOVED AND REPLACED WITH COLD PATCH IF SNOW ACCUMULATIONS ARE PREDICTED.

JACKSON COUNTY ROADS

JAMES PHILP, P.E.
COUNTY ENGINEER

Date	By	Revision

**JCRD302: TYPICAL
TRENCH SECTION & PIPE BACKFILL**


I:\Engineering\LIBRARY\COUNTY\STD_DWG\CURRENT\RD300-Drainage\JCRD302-Trench.dwg

MAR. 2023

NO SCALE



Know what's below.
Call before you dig.



**JACKSON
COUNTY**
Roads