


**NOTES:**

1. CONCRETE SHALL BE: CLASS 3300 - 3/4", 4-6% ENTRAINED AIR.
2. STRUCTURAL STEEL TO BE ASTM A36.
3. STEEL REINFORCING TO BE ASTM A615.
4. MODIFIED VERSIONS OF THIS INLET MAY BE USED WITH PRIOR APPROVAL FROM THE ENGINEER.



**JACKSON COUNTY**  
Roads

JACKSON COUNTY ROADS

JAMES PHILP, P.E.  
COUNTY ENGINEER

Date	By	Revision

JCRD305:  
SHALLOW DITCH INLET

H:\Engineering\LIBRARY\COUNTY\STD\_DWG\CURRENT\RD300-Drainage\JCRD305-InletEntrance.dwg

MAR. 2023

NO SCALE