



NOTES:

1. #4 REBAR @ 12" CENTERS IN WALLS AND FLOOR
2. REINFORCING STEEL GRADE 60 PREFORMED BARS.
3. ALL CONCRETE SHALL BE CLASS 3300-3/4", 4-6% ENTRAINED AIR.

JACKSON COUNTY ROADS

MIKE KUNTZ, P.E.
COUNTY ENGINEER

Date	By	Revision

JCRD307:
CONCRETE HEADWALL

H:\Engineering\LIBRARY\COUNTY\STD_DWG\CURRENT\RD300-Drainage\JCRD307-Headwall.dwg

OCT 2017

NO SCALE

